

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50393752

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*
174065467

Unser Zeichen *Our Reference*
05-Chenbic-16083421 001

Ausstellungsdatum *Date of Issue*
24.11.2017 (day/mo/yr)

Genehmigungsinhaber *License Holder*
MEAN WELL Enterprises Co., Ltd.
No. 28, Wuquan 3rd Rd.,
Wugu Dist., New Taipei City 248
Taiwan

Fertigungsstätte *Manufacturing Plant*
Refer to latest revision
of the annex list of factories

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
EN 60950-1:2006+A11+A1+A12+A2

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Power Supply (Switching Power Supply)

Type Designation : UHP-500-X , UHP-500R-X 15
(X = 4.2, 5, 12, 15, 24, 36, 48)

AC Input :
X= 4.2 AC 100-240V, 50/60Hz, 4A
X= 5 AC 100-240V, 50/60Hz, 4.7A
X=12, 15, 24, 36, 48 AC 100-240V, 50/60Hz, 5.8A

Ambient Temperature :
+45°C for models UHP-500-X, UHP-500R-X (X = 4.2, 5, 12, 15)
+50°C for models UHP-500-X, UHP-500R-X (X = 24, 36, 48)

Protection Class : I
Operation Altitude : 5000m

| Model Name | Output Voltage(Vdc) | Output Current(A) |
|---------------------------|---------------------|-------------------|
| UHP-500-4.2, UHP-500R-4.2 | 4.2 | 80.00 |
| UHP-500-5, UHP-500R-5 | 5.0 | 80.00 |
| UHP-500-12, UHP-500R-12 | 12.0 | 41.70 |
| UHP-500-15, UHP-500R-15 | 15.0 | 33.40 |
| UHP-500-24, UHP-500R-24 | 24.0 | 20.90 |
| UHP-500-36, UHP-500R-36 | 36.0 | 13.90 |
| UHP-500-48, UHP-500R-48 | 48.0 | 10.45 |

ANLAGE (Appendix) : 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich beachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel: +49 221 806-1371 e-mail cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety



Martin Wang

**Anlage Fertigungsstättenliste
/ Attachment List of Factories**

R 50393752 0001



- 1 MEAN WELL Enterprises Co., Ltd.
No. 28, Wuquan 3rd Rd.,
Wugu Dist., New Taipei City 248
Taiwan
- 2 SuZhou MEAN WELL Technology
Co., Ltd.
No. 77, Jian-min Road, Dong-qiao, Pan-
yang Ind. Park, Huang-dai Town, Xiang-
cheng District Suzhou, Jiangsu 215152, P. R. China
- 3 MEAN WELL (GUANGZHOU) ELECTRONICS
CO., LTD HUADU BRANCH
No. 11 Jingu South Road,
Huadong Town, Huadu District,
Guangzhou 510890, P. R. China

Dieser Anhang ersetzt den Vorgänger vom/
This annex replaces the previous annex dated

Datum / Date 24.11.2017

Zertifizierungsstelle
/ Certification Body



Martin Wang