

CERTIFICATE

Issued to:
Applicant:
MEAN WELL Enterprises Co., Ltd.
No.28, Wuquan 3rd Rd, Wugu District
24891 New Taipei City, Taiwan

Licensee:
DongGuan Littelfuse Electronics Co., Ltd
Nanfang East Road, Beice, Humen,
523925 Dongguan, Guangdong Province, China

Product : Surge Protective Device
Trade name(s) : MEAN WELL
Type(s)/model(s) : SPD-10S-277S

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 61643-11:2012
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 3182815


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 6 August 2019 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 31-109616

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



R Zhou
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Surge Protective Device
Trade name(s)	: MEAN WELL
Type(s)/model(s)	: SPD-10S-277S
Number of ports	: One
SPD type (Test class)	: Type 2 (II) & Type 3 (III)
Maximum continuous operating voltage (Uc)	: See further data
Nominal discharge current (In 8/20 μ s)	: 5 kA
Maximum discharge current (Imax 8/20 μ s)	: 10 kA
Open-circuit voltage for Type 3 (III) (Uoc)	: 10 kV
Voltage protection level (Up)	: See further data
Rated load current (IL)	: See further data
Short-circuit current rating (Iscrr)	: 300 A
Modes of protection	: L→N, L→PE and N→PE
Connection	: Pigtail connection
Degree of protection	: IP66
Maximum overcurrent protection	: See further data

TESTS**Test requirements**

EN 61643-11:2012

Test result

The test results are laid down in DEKRA test file 605935400.

Additional information

The list of components is laid down at test report 3177948.51.

Conclusion

The examination proved that all requirements were met.

Factory location

DongGuan Littelfuse Electronics Co., Ltd
Nanfang East Road, Beice, Humen,
523925 Dongguan, Guangdong Province, China

Further data

Type	modes of protection	U_c (V~)	U_{oc} (V~)	I_L (A)	maximum overcurrent protection
SPD-10S-277S	L→N	320	1400	3,5	20 A gG fuse-link
	L→PE		2400		
	N→PE		2200		